

Magnetic Lock Wiring Instructions

A. 12VDC Input:

Required power 0.5Amp(Minimum).

Connect the positive(+)lead from a 12VDC power source to V +.

Connect the ground(-)lead from a 12VDC power source to V -. Check jumper for 12VDC operation.

B. 24VDC Input:

Require power 0.25 Amp(minimum).

Connect the positive(+)lead from a 24 VDC power source to V+.

Connect the ground(-)lead from a 24VDC power source to V-. Check jumper for 24VDC operation.

C. Contacts:

Relay dry contacts are rated 1 Amp at 24VDC for safe operation , do not exceed this rating.

If you require a normally open switch ,connect the wires from the system to COM and NO.

If you require a normally closed switch ,connect the wires from the system to COM and NC. Important!

If power switch is not wired between DC source voltage and magnet ,it will take a longer time to de-energize the magnet simulating residual magnetism.(see below)

Printed Circuit Board Schematic

